


Bolted Tee Tap for ACCC



Catalog Number Configuration for Bolted Tee Taps

D11567 - **AFL Code** **EHV** - **ACCC**

Blank = voltage <345 kV
EHV = voltage ≥345 kV

Notes

- For 345 kV and above, add suffix "EHV" to AFL No.
For example: D11567-LEHV-ACCC
- For more information, contact AFL at 1.800.866.7385.

AFL NO. BOLTED TEE TAP	ACCC	CONDUCTOR		DIAMETER		CORE DIAMETER		WEIGHT		CORE RATED STRENGTH		COND. RATED STRENGTH	
	SIZE	(KCMIL)	(MM²)	(IN)	(MM)	(IN)	(MM)	(LB/ KFT)	(KG/ KM)	(LBF)	(KN)	(LBF)	(KN)
D11567-K-ACCC	PASADENA	305	154.4	0.616	15.65	0.235	5.97	321	478	13,600	60.4	15,500	68.9
D11567-K-ACCC	HELSINKI	297	150.6	0.616	15.65	0.235	5.97	317	471	13,600	60.4	15,500	68.9
D11567-G-ACCC	JAIPUR	309	156.7	0.650	16.50	0.305	7.75	349	519	22,900	101.7	24,900	110.8
D11567-BB-ACCC	ZADAR	356	180.3	0.673	17.09	0.280	7.11	386	574	19,300	85.7	21,600	96.1
D11567-BC-ACCC	ROVINJ	378	191.6	0.673	17.10	0.235	5.97	392	583	13,600	60.4	16,000	71.2
D11567-BC-ACCC	OSTRICH (OCEANSIDE)	383	194.2	0.680	17.27	0.235	5.97	396	589	13,600	60.4	16,000	71.2
D11567-L-ACCC	LINNET (LA JOLLA)	430	218.1	0.720	18.29	0.235	5.97	440	655	13,600	60.4	16,300	72.5
D11567-L-ACCC	COPENHAGEN	434	219.9	0.720	18.29	0.235	5.97	444	661	13,600	60.4	16,400	72.8
D11567-M-ACCC	ORIOLE (OXNARD)	439	222.3	0.741	18.82	0.280	7.11	463	689	19,300	85.7	22,100	98.3
D11567-M-ACCC	REYKJAVIK	440	223.1	0.741	18.82	0.280	7.11	466	694	19,300	85.7	22,100	98.3
D11567-BD-ACCC	GDANSK	491	248.7	0.756	19.20	0.235	5.97	499	743	13,600	60.4	16,700	74.3
D11567-N-ACCC	GLASGOW	467	236.7	0.769	19.53	0.305	7.75	492	732	22,900	101.7	25,900	115.0
D11567-N-ACCC	WACO	454	230.1	0.770	19.56	0.305	7.75	485	721	22,900	101.7	25,800	114.8
D11567-P-ACCC	LAREDO	530	268.4	0.807	20.50	0.280	7.11	548	816	19,300	85.7	22,700	101.0
D11567-P-ACCC	CASABLANCA	540	273.6	0.807	20.50	0.280	7.11	561	834	19,300	85.7	22,700	101.1
D11567-R-ACCC	MONTE CARLO	451	228.5	0.818	20.78	0.415	10.54	537	799	42,300	188.3	45,200	201.2
D11567-S-ACCC	ULS MONTE CARLO	451	228.5	0.819	20.79	0.415	10.54	537	799	50,700	225.6	53,600	238.6
D11567-B-ACCC	HAWK (HERMOSA/LISBOON)	611	309.7	0.858	21.79	0.280	7.11	625	930	19,300	85.7	23,200	103.2
D11567-B-ACCC	LISBON	623	315.5	0.858	21.79	0.280	7.11	637	948	19,300	85.7	23,300	103.5
D11567-F-ACCC	IRVING	609	308.8	0.882	22.40	0.345	8.76	649	965	29,300	130.2	33,200	147.7
D11567-F-ACCC	OSLO	619	313.8	0.882	22.40	0.345	8.76	659	981	29,300	130.2	33,200	147.8
D11567-T-ACCC	DOVE (DOHNEY)	714	361.5	0.927	23.55	0.305	7.75	728	1083	22,900	101.7	27,500	122.3
D11567-T-ACCC	AMSTERDAM	725	367.4	0.927	23.55	0.305	7.75	740	1101	22,900	101.7	27,500	122.4
D11567-X-ACCC	ULS 25mm	753	381.8	0.984	25.00	0.415	10.54	817	1216	50,700	225.6	55,600	247.2
D11567-W-ACCC	GROSBEAK (GOLETA)	821	416.2	0.990	25.15	0.320	8.13	837	1245	25,200	112.0	30,400	135.2
D11567-W-ACCC	BRUSSELS	832	421.4	0.990	25.15	0.320	8.13	850	1265	25,200	112.0	30,500	135.7
D11567-Y-ACCC	ULS LEIPZIG	802	406.4	0.990	25.15	0.375	9.53	842	1253	41,300	183.5	46,600	207.3
D11567-BE-ACCC	STOCKHOLM 2L	914	463.3	1.039	26.39	0.345	8.76	937	1395	29,300	130.2	35,100	156.2
D11567-BE-ACCC	STOCKHOLM 3L	895	453.7	1.039	26.39	0.345	8.76	919	1368	29,300	130.2	35,000	155.7
D11567-BF-ACCC	LUBBOCK	904	458.0	1.040	26.42	0.345	8.76	924	1376	29,300	130.2	35,100	156.1
D11567-Z-ACCC	GALVESTON	1011	512.4	1.090	27.69	0.345	8.76	1025	1526	29,300	130.2	35,700	158.8
D11567-Z-ACCC	WARSAW	1002	507.5	1.091	27.71	0.345	8.76	1021	1520	29,300	130.2	35,700	158.7
D11567-A-ACCC	DRAKE (DEL MAR)	1026	519.7	1.108	28.14	0.375	9.53	1052	1565	34,600	153.8	41,200	183.3
D11567-A-ACCC	DUBLIN	1035	524.5	1.108	28.14	0.375	9.53	1064	1583	34,600	153.8	41,200	183.3
D11567-AB-ACCC	PLANO	1059	536.8	1.127	28.63	0.345	8.76	1073	1597	29,300	130.2	36,000	160.1
D11567-AB-ACCC	HAMBURG	1078	546.4	1.127	28.63	0.345	8.76	1093	1627	29,300	130.2	36,200	160.9
D11567-AC-ACCC	KOLKATA	1073	543.5	1.127	28.63	0.375	9.53	1104	1643	34,600	153.8	41,400	184.0
D11567-AA-ACCC	CURLEW (CRESCENT)	1033	523.4	1.140	28.96	0.415	10.54	1082	1610	42,300	188.3	49,000	218.0

Bolted Tee Taps for ACCC (cont.)

AFL NO.	ACCC	CONDUCTOR		DIAMETER		CORE DIAMETER		WEIGHT		CORE RATED STRENGTH		COND. RATED STRENGTH	
BOLTED TEE TAP		SIZE	(KCMIL)	(MM²)	(IN)	(MM)	(IN)	(MM)	(LB/KFT)	(KG/KM)	(LBF)	(KN)	(LBF)
D11567-AD-ACCC	ULS MAHAKAM	1075	544.9	1.142	29.01	0.415	10.54	1127	1677	50,700	225.6	57,600	256.3
D11567-AE-ACCC	CORPUS CHRISTI	1103	558.9	1.146	29.11	0.345	8.76	1113	1657	29,300	130.2	36,300	161.5
D11567-AE-ACCC	MILAN	1120	567.7	1.146	29.11	0.345	8.76	1133	1686	29,300	130.2	36,400	162.1
D11567-AF-ACCC	ARLINGTON	1151	583.2	1.177	29.90	0.375	9.53	1173	1745	34,600	153.8	41,900	186.4
D11567-AF-ACCC	ROME	1169	592.5	1.177	29.90	0.375	9.53	1192	1774	34,600	153.8	42,100	187.1
D11567-AG-ACCC	CARDINAL (CARLSBAD)	1222	619.1	1.198	30.43	0.345	8.76	1225	1823	29,300	130.2	37,100	165.0
D11567-AG-ACCC	VIENNA	1242	629.2	1.198	30.43	0.345	8.76	1245	1853	29,300	130.2	37,200	165.5
D11567-AH-ACCC	FORT WORTH	1300	658.9	1.240	31.50	0.375	9.53	1312	1952	34,600	153.8	42,900	190.8
D11567-AH-ACCC	BUDAPEST	1319	668.3	1.240	31.50	0.375	9.53	1333	1984	34,600	153.8	43,000	191.4
D11567-AK-ACCC	PRAGUE	1363	690.7	1.251	31.78	0.345	8.76	1364	2031	29,300	130.2	38,000	169.0
D11567-AL-ACCC	ULS PRAGUE	1363	690.7	1.251	31.78	0.345	8.76	1364	2031	34,900	155.1	43,800	194.8
D11567-AM-ACCC	MUMBAI	1353	685.4	1.251	31.78	0.375	9.53	1367	2035	34,600	153.8	43,200	192.0
D11567-AK-ACCC	EL PASO	1350	684.0	1.252	31.80	0.345	8.76	1345	2002	29,300	130.2	37,900	168.6
D11567-AL-ACCC	ULS EL PASO	1350	684.0	1.252	31.80	0.345	8.76	1345	2002	34,900	155.1	43,500	193.5
D11567-H-ACCC	MUNICH	1447	733.1	1.293	32.84	0.375	9.53	1458	2170	34,600	153.8	43,800	195.0
D11567-H-ACCC	BEAUMONT	1429	723.9	1.294	32.87	0.375	9.53	1436	2136	34,600	153.8	43,700	194.4
D11567-AN-ACCC	SAN ANTONIO	1475	747.3	1.315	33.40	0.385	9.78	1486	2212	36,400	162.1	45,900	204.2
D11567-AN-ACCC	LONDON	1498	759.0	1.315	33.40	0.385	9.78	1511	2248	36,400	162.1	46,000	204.8
D11567-AP-ACCC	BITTERN (BALBOA)	1582	801.4	1.345	34.16	0.345	8.76	1566	2331	29,300	130.2	39,400	175.3
D11567-AR-ACCC	ULS BITTERN (BALBOA)	1582	801.4	1.345	34.16	0.345	8.76	1566	2331	34,900	155.1	45,000	200.2
D11567-AP-ACCC	PARIS	1606	813.7	1.345	34.16	0.345	8.76	1590	2366	29,300	130.2	39,600	175.9
D11567-AW-ACCC	BORDEAUX	1738	880.8	1.408	35.76	0.415	10.54	1859	2766	42,300	188.3	53,500	237.9
D11567-AS-ACCC	ANTWERP	1865	944.8	1.451	36.86	0.385	9.78	1855	2760	36,400	162.1	48,400	215.2
D11567-AT-ACCC	ULS ANTWERP	1865	944.8	1.451	36.86	0.385	9.78	1855	2760	43,500	193.5	55,600	247.3
D11567-AS-ACCC	DALLAS	1795	909.5	1.452	36.88	0.385	9.78	1795	2671	36,400	162.1	47,900	213.1
D11567-AT-ACCC	ULS DALLAS	1795	909.5	1.452	36.88	0.385	9.78	1795	2671	43,500	193.5	55,000	244.7
D11567-AX-ACCC	LAPWING (LAGUNA)	1949	987.5	1.504	38.20	0.385	9.78	1940	2887	36,400	162.1	48,900	217.5
D11567-E-ACCC	BERLIN (MADRID-ICE)	1986	1006.5	1.504	38.20	0.415	10.54	1982	2949	42,300	188.3	55,100	245.0
D11567-AX-ACCC	MADRID	1999	1013.0	1.504	38.20	0.385	9.78	1981	2948	36,400	162.1	49,200	219.1
D11567-E-ACCC	HOUSTON	1927	976.6	1.506	38.25	0.415	10.54	1934	2878	42,300	188.3	54,700	243.3
D11567-AY-ACCC	FALCON (SANOMA)	2045	1036.2	1.545	39.24	0.415	10.54	2045	3044	42,300	188.3	55,400	246.4
D11567-D-ACCC	CHUKAR (CARMEL)	2242	1135.8	1.604	40.74	0.395	10.03	2220	3303	38,400	170.6	52,700	234.4
D11567-BA-ACCC	CHUKAR II (CAPIST-RANO)	2606	1320.3	1.720	43.69	0.395	10.03	2570	3825	38,400	170.6	55,100	245.1
D11567-AZ-ACCC	BLUEBIRD (BIG SUR)	2741	1388.7	1.762	44.75	0.415	10.54	2703	4022	42,300	188.3	59,900	266.4
D11567-AZ-ACCC	ATHENS	2782	1409.6	1.762	44.75	0.415	10.54	2732	4066	42,300	188.3	60,200	267.6